

# UL1424 FPL/FPLR

## CERTIFICATE OF COMPLIANCE

Certificate Number 20180202-E497309  
Report Reference 20180202  
Issue Date 2018-FEBRUARY-02

Issued to: HANGZHOU HONGFENG CABLE CO., LTD

Linglong St, Lin' An  
Zhejiang 311301 CHINA

This is to certify that  
representative samples of

POWER-LIMITED FIRE ALARM CABLE  
USL: Power Limited Fire Alarm Cables, Types FPLR and  
FPL, rated 60°C - 105°C.  
CNL: Fire Alarm and Signal Cable, Types FAS, FAS FT1,  
FAS105, FAS105 FT1, FAS90 and FAS90 FT1, rated 60°C  
- 105°C

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1424, Power-Limited Fire-Alarm Circuit Cables;  
C22.2 No. 208-14, Fire-Alarm and Signal Cable

Additional Information: See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

*B. Mahlenz*

Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/about/locations>.

